



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	Hardwood Timber Min 670kg/m ³ Density / Fire Rated Plasterboard Ceiling	FireMastic-300™ - 50mm Wide x 25mm Deep	Hardwood Timber Min 670kg/m ³ Density / Fire Rated Plasterboard Ceiling		FRL -/60/60	Up to 50mm Wide Gap	Up to 50mm Wide Gap
2	Insulation						
3	Fire Rated Plasterboard						
4	PE Backing Rod						
5	FireMastic-300™ - 50mm Wide x 25mm Deep						
6	Steel Bracket						
		Secondary Fire Stopping Product					
		PE Backing Rod					
		Tertiary Fire Stopping Product					

LIMITATION
 BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Passive Fire Pty Ltd. All rights reserved.



Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Ceiling		
Category 2	Linear Gap Seal		
Category 3	-		
Test Standard	AS1530.4:2014/AS4072.1-2005		
Test Reference	PFITS FAR190042		
Drawing Number	C-LG-016		
Product DWG ID	FM3-038		
Drawn By	EG	Rev	01
Date of Issue	08/02/2022		