



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations			
1 2 3	Pyrogard Fire Foam - 50mm Wide x 250mm Deep Aerated Autoclaved Concrete 670kg/m ³ Mineral Rock Fibre 160kg/m ³ 50mm x 50mm	Pyrogard Fire Foam - 50mm Wide x 250mm Deep	Aerated Autoclaved Concrete 670kg/m ³	Minimum 250mm Thick	FRL -/180/180	Maximum Gap Width 50mm	Maximum Gap Width 50mm		SIVE FIR	E
								Sales & Technical	1300 502 677	
								International	+61 2 9531 8591	
								Web	bossfire.com	
								Drawing Information:		
		Secondary Fire Stopping Product						Category 1	Floor	
		Mineral Rock Fibre 160kg/m³ 50mm x 50mm						Category 2	Linear Gap Seal	
								Category 3	-	
				BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the This information was deemed to be correct at the time of publication. Should any data come to B				Test Standard	AS1530.4:2014/AS4072.1-20	005
		Tertiary Fire Stopping Product		attention relating to the fire resist	tance or performance of	the product described, BOSS Passive Fi	re Pty Ltd reserve the	Test Reference	CSIRO FCO-3001	
				right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and due information may change without notice. The information contained herein has been developed as a guide only and it does not constitute				Drawing Number	F-LG-031	
				compliance of all applications. Ea	compliance of all applications. Each project and/or application may have specific require investigate these carefully. Ensure that you have read and understood the appropriate c			Product DWG ID	PG-004	
				needs, and ensure you seek acc	eptance from the Certif	ing Authority or compliance inspector before contact BOSS Technical Services. +61 2 95	fore installation. For 2 9531 8591	Drawn By	EG Rev 02	2
				Copyright © 2020 BOSS Passive	e Fire Pty Ltd. All rights			Date of Issue	08/02/2022	