



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	Pyrogard Fire Foam - 35mm Wide x 250mm Deep	Pyrogard Fire Foam - 35mm Wide x 250mm Deep	Aerated Autoclaved Concrete 670kg/m ³	Minimum 250mm Thick	FRL -/60/60	Maximum Gap Width 35mm	Maximum Gap Width 35mm
2	Aerated Autoclaved Concrete 670kg/m ³						
		Secondary Fire Stopping Product					
		Tertiary Fire Stopping Product					

LIMITATION
 BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Passive Fire Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Floor		
Category 2	Linear Gap Seal		
Category 3	-		
Test Standard	AS1530.4:2014/AS4072.1-2005		
Test Reference	CSIRO FCO-3001		
Drawing Number	F-LG-032		
Product DWG ID	PG-005		
Drawn By	EG	Rev	02
Date of Issue	08/02/2022		