



| OTHER APPLICABLE SUBSTRATES |          |           |
|-----------------------------|----------|-----------|
| MASONRY                     | CONCRETE | ACC/HEBEL |
|                             |          |           |

| Component Schedule | Component Name  | Primary Fire Stopping Product          | Applicable Substrates                            | Min Substrate Thickness (If Applicable) | Applicable FRL | Service Specifications | Limitations |
|--------------------|---|--|--|---|----------------|------------------------|-------------|
| 1<br>2<br>3<br>4   | Concrete / Masonry Wall<br>Fire Rated Plasterboard, ACC, Concrete & Masonry<br>FireMastic-HPE™ - Nominal Depth 25mm<br>Steel Stud | FireMastic-HPE™                        | Fire Rated Plasterboard, AAC, Concrete & Masonry | Min 120mm Thick                         | -/120/120      | Gaps 10-20mm wide      |             |
|                    |   | <b>Secondary Fire Stopping Product</b> |  |   |                |                        |             |
|                    |   | <b>Tertiary Fire Stopping Product</b>  |  |   |                |                        |             |

|                              |                        |            |    |
|------------------------------|------------------------|------------|----|
| <b>Sales &amp; Technical</b> | 1300 502 677           |            |    |
| <b>International</b>         | +61 2 9531 8591        |            |    |
| <b>Web</b>                   | bossfire.com           |            |    |
| <b>Drawing Information:</b>  |                        |            |    |
| <b>Category 1</b>            | Wall                   |            |    |
| <b>Category 2</b>            | Linear Gap Seal        |            |    |
| <b>Category 3</b>            | -                      |            |    |
| <b>Test Standard</b>         | AS1530.4-2014/AS4072.1 |            |    |
| <b>Test Reference</b>        | CSIRO-2990B            |            |    |
| <b>Drawing Number</b>        | W-LG-001               |            |    |
| <b>Product DWG ID</b>        | HPE-022                |            |    |
| <b>Drawn By</b>              | EG                     | <b>Rev</b> | 03 |
| <b>Date of Issue</b>         | 21/09/2020             |            |    |

**LIMITATION**  
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.  
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.