



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3 4	FireMastic-300™ See Applicable Substrates Masonry Steel Beam	FireMastic-300™ - 10mm Wide x Depth of plasterboard	Perimeter seal to: Fire Rated Plasterboard AAC/ Hebel Speedpanel / Korok AFS Dintel Shaftliner Concrete Solid & Hollow Masonry Metal Clad AAC with an established FRL	Deflection head seal to fire rated walls as listed in applicable substrates.	Up to FRL -/300/300	Up to 10mm Wide Gap	Up to 10mm Wide Gap
		Secondary Fire Stopping Product					
		Tertiary Fire Stopping Product					

LIMITATION
 BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Passive Fire Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Wall		
Category 2	Linear Gap Seal		
Category 3	-		
Test Standard	AS1530.4:2014/AS4072.1-2005		
Test Reference	Branz FAR 3821		
Drawing Number	W-LG-014		
Product DWG ID	FM3-036		
Drawn By	EG	Rev	01
Date of Issue	08/02/2022		