



| Component Schedule | Component Name | Primary Fire Stopping Product | Applicable Substrates | Min Substrate Thickness (If Applicable) | Applicable FRL | Service Specifications | Limitations |
|--------------------|--|---|--|---|----------------|------------------------|---------------------|
| 1 | Hardwood Timber Min 670kg/m ³ Density / Fire Rated Plasterboard Ceiling | FireMastic-300™ - 50mm Wide x 25mm Deep | Hardwood Timber Min 670kg/m ³ Density / Fire Rated Plasterboard Ceiling | | FRL -/60/60 | Up to 50mm Wide Gap | Up to 50mm Wide Gap |
| 2 | FireMastic-300™ - 50mm Wide x 25mm Deep | | | | | | |
| 3 | PE Backing Rod | | | | | | |
| 4 | Steel Bracket | | | | | | |
| 5 | Insulation | | | | | | |
| 6 | Fire Rated Plasterboard | | | | | | |
| | | Secondary Fire Stopping Product | | | | | |
| | | PE Backing Rod | | | | | |
| | | Tertiary Fire Stopping Product | | | | | |
| | | | | | | | |

LIMITATION
 BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Passive Fire Pty Ltd. All rights reserved.



| | | | |
|------------------------------|-----------------------------|------------|----|
| Sales & Technical | 1300 502 677 | | |
| International | +61 2 9531 8591 | | |
| Web | bossfire.com | | |
| Drawing Information: | | | |
| Category 1 | Wall | | |
| Category 2 | Linear Gap Seal | | |
| Category 3 | - | | |
| Test Standard | AS1530.4:2014/AS4072.1-2005 | | |
| Test Reference | PFITS FAR190042 | | |
| Drawing Number | W-LG-017 | | |
| Product DWG ID | FM3-039 | | |
| Drawn By | EG | Rev | 01 |
| Date of Issue | 08/02/2022 | | |