



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3	Pyrogard Fire Foam - 15mm Wide x 250mm Deep Aerated Autoclaved Concrete 670kg/m <sup>3</sup> Softwood 437.95 kg/m <sup>3</sup>	Pyrogard Fire Foam - 15mm Wide x 250mm Deep	Aerated Autoclaved Concrete 670kg/m <sup>3</sup> / Softwood 437.95 kg/m <sup>3</sup> OR Aerated Autoclaved Concrete 670kg/m <sup>3</sup> / Hardwood 680.76kg/m <sup>3</sup>	Minimum 250mm Thick	FRL -/180/180	Maximum Gap Width 15mm	Maximum Gap Width 15mm
		<b>Secondary Fire Stopping Product</b>					
		<b>Tertiary Fire Stopping Product</b>					

**LIMITATION**  
BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice.  
The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
Copyright © 2020 BOSS Passive Fire Pty Ltd. All rights reserved.

<b>Sales &amp; Technical</b>	1300 502 677		
<b>International</b>	+61 2 9531 8591		
<b>Web</b>	bossfire.com		
<b>Drawing Information:</b>			
<b>Category 1</b>	Wall		
<b>Category 2</b>	Linear Gap Seal		
<b>Category 3</b>	-		
<b>Test Standard</b>	AS1530.4:2014/AS4072.1-2005		
<b>Test Reference</b>	CSIRO FCO-3001		
<b>Drawing Number</b>	W-LG-028		
<b>Product DWG ID</b>	PG-001		
<b>Drawn By</b>	EG	<b>Rev</b>	02
<b>Date of Issue</b>	08/02/2022		