



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3 4 5	Fire Rated Plasterboard, Concrete & Masonry MaxiCollar™ 32mm FireMastic-HPE™ - Nominal Depth of MaxiCollar™ Plasterboard Screw 25mm Up to 32mm PP-R Pipe (Aquatherm)	MaxiCollar™ 32mm	Fire Rated Plasterboard, Concrete & Masonry	Min 118mm Thick	Up to FRL -/60/60	Up to 32mm PP-R Pipe (Aquatherm)	32mm Aperture for 20mm Pipe 38mm Aperture for 32mm Pipe
		<b>Secondary Fire Stopping Product</b>					
		FireMastic-HPE™ (Infill) 25mm Depth of Collar					
		<b>Tertiary Fire Stopping Product</b>					

**LIMITATION**  
BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.  
The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

<b>Sales &amp; Technical</b>	1300 502 677		
<b>International</b>	+61 2 9531 8591		
<b>Web</b>	bossfire.com		
<b>Drawing Information:</b>			
<b>Category 1</b>	Wall		
<b>Category 2</b>	Service Penetration		
<b>Category 3</b>	Plastic Pipes		
<b>Test Standard</b>	AS1530.4-2014/AS4072.1		
<b>Test Reference</b>	FRT180403b.1		
<b>Drawing Number</b>	W-SP-PLS-006		
<b>Product DWG ID</b>	MC-005		
<b>Drawn By</b>	EG	<b>Rev</b>	03
<b>Date of Issue</b>	14/09/2020		