Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations		
1 2 3 4	FR Plasterboard, Concrete or Masonry FireMastic-300™ - 30mm x 30mm Surface Fillet TPS Power Cables 2C+E 2.5mm² - 10mm Annular Gap Steel Stud	FireMastic-300™	FR Plasterboard, Concrete, Masonry	Min 144mm Thick	-/120/120	Bundle 7 x TPS Power Cables 2C+E 2.5mm²	Aperture 30mm Dia		
		Secondary Fire Stopping Product							
		Tertiary Fire Stopping Product							

BOSS PASSIVE FIRE

Sales & Technical	1300 502 677
International	+61 2 9531 8591
Web	bossfire.com

Drawing Information:	
Category 1	Wall
Category 2	Service Penetration
Category 3	Power Cables
Test Standard	AS1530.4-2014/AS4072.1
Test Reference	SFC FRT180403i.1
Drawing Number	W-SP-POW-012
Product DWG ID	FM3-011
Drawn By	EG	**Rev**	03
Date of Issue	07/12/2020