



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	CAT6 Cables	BOSS MaxiCollar™ 80mm	Fire Rated Plasterboard / GIB Ceiling Floor System	26mm Plasterboard - 235mm Overall System	Up to -/90/90 RISF Limit 53mins	-CAT6 Cables -TPS Cables 2.5mm² -uPVC Conduit -PairCoil-15.88/9.52mm (13mm Lagging)	Aperture 72mm
2	TPS Cables 2.5mm²						
3	uPVC Conduit						
4	PairCoil-15.88/9.52mm (13mm Lagging)						
5	FireMastic-300™						
6	19mm Particle Board Flooring						
7	190mm x 45mm Timber						
8	13mm Fire Rated Plasterboard						
9	Mechanical Fixing-Hollow Wall Anchors						
10	BOSS MaxiCollars™ 80mm						
11	FireMastic-HPE™						
		<b>Secondary Fire Stopping Product</b>					
		FireMastic-HPE™					
		<b>Tertiary Fire Stopping Product</b>					
		FireMastic-300™					

**LIMITATION**  
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.  
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

<b>Sales &amp; Technical</b>	1300 502 677		
<b>International</b>	+61 2 9531 8591		
<b>Web</b>	bossfire.com		
<b>Drawing Information:</b>			
<b>Category 1</b>	Ceiling		
<b>Category 2</b>	Service Penetration		
<b>Category 3</b>	PairCoil Bundles		
<b>Test Standard</b>	AS1530.4-2014/AS4072.1		
<b>Test Reference</b>	SFC FRT 180474.1		
<b>Drawing Number</b>	C-SP-PCL-001		
<b>Product DWG ID</b>	MC-002		
<b>Drawn By</b>	EG	<b>Rev</b>	04
<b>Date of Issue</b>	20/07/2020		