



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3 4 5 6	3x 2C+E Mains Cable FireMastic-300™ 19mm Particle Board Flooring 190mm x 45mm Timber 13mm Fire Rated Plasterboard FireMastic-HPE™	FireMastic-HPE™	Fire Rated Plasterboard / GIB Ceiling Floor System	26mm Plasterboard - 235mm Overall System	Up to -/90/90 RISF Limit 54mins	3x 2C+E Mains Cable (Approx 10.6mm Dia)	Aperture 51mm
		Secondary Fire Stopping Product					
		FireMastic-300™					
		Tertiary Fire Stopping Product					

LIMITATION
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Ceiling		
Category 2	Service Penetration		
Category 3	Power Cables		
Test Standard	AS1530.4-2014/AS4072.1		
Test Reference	SFC FRT 180474.1		
Drawing Number	C-SP-POW-003		
Product DWG ID	HPE-002		
Drawn By	EG	Rev	03
Date of Issue	20/07/2020		