



Component C Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations		nee
2 TI	150mm Concrete Thermobreak Lagged Steel Copper & Iron Pipes - 32mm	MaxiCollar™ - Fitted Underside FireMastic-300™	Minimum 150mm Concrete	150mm	-/120/120	Thermobreak Lagged Steel Copper & Iron Pipes - 32mm-159mm	30-50mm Thick Thermobreak Lagging	PASS	SIVE FIRE
	Fhermobreak Lagged Steel Copper & Iron Pipes 32mm-159mm	- 10mm x 10mm fillet on top side only - Annular Gap Max 5mm wide x Min 25mm						Sales & Technical	1300 502 677
4 Fi	FireMastic-300™	depth both sides						International	+61 2 9531 8591
32	P40-MAK Wrap 600mm Both Sides to suit 32mm-159mm Pipes							Web	bossfire.com
	P40-MAK Wrap 300mm Both Sides to suit 32mm Pipes BOSS Batt - 2x 50mm Layers - Used to firestop oversized apertures			LIMITATION				Drawing Information:	
		Secondary Fire Stopping Product						Category 1	Floor
	MaxiCollar [™]	P40-MAK Wrap						Category 2	Service Penetration
								Category 3	Insulated Metal Pipes
				BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowle This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety				Test Standard	AS1530.4-2014/AS4072.1
		Tertiary Fire Stopping Product		attention relating to the fire resista	ance or performance of	the product described, BOSS Fire & Safety Pty L Safety strive to constantly improve and develop pr	ty Pty Ltd reserve the	Test Reference	FAS 190346 R1.4
				information may change without notice. The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your			Drawing Number	F-SP-IMT-005	
							l you should	Product DWG ID	MC-008
				needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591				Drawn By	EG Rev 04
				Copyright © 2020 BOSS Fire & Sa				Date of Issue	05/03/2021