



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	150mm Concrete Floor	FireMastic-300™ - 10mm x 10mm Surface Fillet Top Side Only - Annular Gap Min 25mm Depth Both Sides Secondary Fire Stopping Product P40-MAK Wrap - 32mm Pipe - 300mm - 32mm-159mm Pipe - 600mm Tertiary Fire Stopping Product BOSS Batt + BOSS FirePillows-240™	Minimum 150mm Concrete	150mm	-I20/I20	Steel Copper & Iron Pipes - 32mm-159mm Steel Copper & Iron Pipes - 32mm-100mm	
2	Steel, Copper & Iron Pipes - 32mm-159mm						
3	FireMastic-300™						
4	P40-MAK Wrap - Top Side Only - 32mm Pipe - 300mm - 32mm-159mm Pipe - 600mm						
5	BOSS Batt - 2x 50mm Layers - Used to firestop oversized apertures						
6	BOSS FirePillows-240™						
7	Steel, Copper & Iron Pipes - 30mm-100mm						

LIMITATION
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Floor		
Category 2	Service Penetration		
Category 3	Metal Pipes		
Test Standard	AS1530.4-2014/AS4072.1		
Test Reference	FAS 190346 R1.4		
Drawing Number	F-SP-MET-012		
Product DWG ID	FM3-014		
Drawn By	EG	Rev	03
Date of Issue	25/02/2021		