



TRAPEZOIDAL PIECES OF BOSS BATT TO BOTH SIDES OF PENETRATION

Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	22 x TPS Cables 2C+E 2.5mm <sup>2</sup>	FireMastic-HPE™ - 25mm deep	Comflor® 60 - Composite Floor System	Min 75mm Profile	FRL -/120/120	22 x TPS Cables 2C+E 2.5mm <sup>2</sup>	Aperture 76mm
2	FireMastic-HPE™ - 25mm deep						
3	Comflor® 60						
4	BOSS Batt						
5	Mechanical Fixing with Washer						
		<b>Secondary Fire Stopping Product</b>					
		BOSS Batt					
		<b>Tertiary Fire Stopping Product</b>					

**LIMITATION**  
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.  
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

<b>Sales &amp; Technical</b>	1300 502 677		
<b>International</b>	+61 2 9531 8591		
<b>Web</b>	bossfire.com		
<b>Drawing Information:</b>			
<b>Category 1</b>	Floor		
<b>Category 2</b>	Service Penetration		
<b>Category 3</b>	Power Cables		
<b>Test Standard</b>	AS1530.4:2014/AS4072.1-2005		
<b>Test Reference</b>	RIR FRT 180137.2		
<b>Drawing Number</b>	F-SP-POW-021		
<b>Product DWG ID</b>	HPE-027		
<b>Drawn By</b>	EG	<b>Rev</b>	02
<b>Date of Issue</b>	24/08/2021		