

Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations			
1 2 3 4	FireMastic-300™ - 30mm Wide x 15mm Deep PE Backing Rod Masonry Mild Steel	FireMastic-300™ - 30mm Wide x 15mm Deep	Masonry / Mild Steel	250mm Thick	FRL -/300/90	Up to 30mm Wide Gap				F I R E
								Sales & Technical	1300 502 677	
								International	+61 2 9531 859	J1
								Web	bossfire.com	
								Drawing Information:		
		Secondary Fire Stopping Product						Category 1	Wall	
		PE Backing Rod						Category 2	Linear Gap Seal	
								Category 3	-	
				BOSS Passive Fire Pty Ltd has p		technical information in good faith and to the best of its knowledge. ne of publication. Should any data come to BOSS Passive Fire		Test Standard	AS1530.4:2014/AS4072.1-2005	
		Tertiary Fire Stopping Product		attention relating to the fire resistance or performance or right to amend this document or drawing. BOSS Passiv		the product described, BOSS Passive Fir	e Pty Ltd reserve the	Test Reference	Branz FAR 3821	
				information may change without r	notice.	s a guide only and it does not constitute a		Drawing Number	W-LG-004	
				compliance of all applications. Ea	ch project and/or applic	cation may have specific requirements and	d you should	Product DWG ID	FM3-026	
				investigate these carefully. Ensure that you have read and understood the appropriate certific needs, and ensure you seek acceptance from the Certifying Authority or compliance inspecto updates on the range of BOSS Fire® certification please contact BOSS Technical Services.			before installation. For	Drawn By	EG	Rev 01
				Copyright © 2020 BOSS Passive			2 3331 0331	Date of Issue	08/02/2022	

