



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	Concrete Block, Masonry Wall	FirePillows-240™	Concrete Block, Masonry Wall	Min 140mm Thick	-/180/120	Pack of 60 (10 x 6) 50 pair communication cables	Nominal dims 600mm wide (or greater) x 400mm high
2	FirePillows-240™						
3	FireMastic-300™ - 20mm x 20mm fillet + between pillows + pillows to substrate						
4	Telecommunication cable - (Appendix D2 Config - AS1530.4)						
5	Cable Tray	Secondary Fire Stopping Product					
6	P40-MAK Wrap - 2x Layer - 300mm	FireMastic-300™					
7	Metal Tie Wire	Tertiary Fire Stopping Product					
		P40-MAK Wrap					

LIMITATION
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.



Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Wall		
Category 2	Service Penetration		
Category 3	Data Cables		
Test Standard	AS1530.4-2014/AS4072.1		
Test Reference	FAS190042		
Drawing Number	W-SP-DAT-004		
Product DWG ID	FP-001		
Drawn By	EG	Rev	03
Date of Issue	07/12/2020		