



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations		266
1 2 3 4 5	Wall (See Applicable Substrates) PenoPatch™ 60mm 12mm Nails or Screws depending on substrate 5 x CAT6 Data Cables 3 x CAT6 Data Cables	PenoPatch™ 60mm	Min 118mm Thick Walls: -FR Plasterboard / GIB -Concrete -Masonry -AAC / Hebel Walls with Build Up to Min 118mm: -Speedpanel & Korok -AAC / Hebel Build up options - 100mm clearance from perimeter of service: -BOSS Batt -FR Plasterboard (Edge to be sealed with 20mm deep sealant)	118mm	-/60/30 -/60/60	Aperture 20mm Dia 5 x CAT6 Data Cables (-/60/30) 3 x CAT6 Data Cables (-/60/60) with wrapped PenoPatch	masonry nails (min 12mm long). In AAC / Hebel, Speedpanel & Korok wall PenoPatch to be fixed using two metal screws (min 12mm long).	PASS	S I V E F I R E
								Sales & Technical	1300 502 677
								International	+61 2 9531 8591
		Secondary Fire Stopping Product						Web	bossfire.com
								Drawing Information:	
								Category 1	Wall
								Category 2	Service Penetration
				LIMITATION				Category 3	Data Cables
				BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's				Test Standard	AS1530.4: 2014/AS4072.1-2005
		Tertiary Fire Stopping Product		attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this			Test Reference	FAS 190100	
				information may change without notice. The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For				Drawing Number	W-SP-DAT-010
								Product DWG ID	PP-003
								Drawn By	EG Rev 05
				updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.			Date of Issue	01/07/2021	