



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations		066
	Fire Rated Plasterboard, ACC, Concrete & Masonry FireMastic-HPE™ - Nominal Depth 25mm Copper Pipe 15-60mm Dia	FireMastic-HPE™	Fire Rated Plasterboard, ACC, Concrete & Masonry	Min 120mm Thick	-/120/-	Copper Pipe 15-60mm Dia	Apperture to suit 20mm wide annular gap around service	P A S	S I V E F I R E
								Sales & Technical	1300 502 677
								International	+61 2 9531 8591
								Web	bossfire.com
								Drawing Information:	
		Secondary Fire Stopping Product						Category 1	Wall
								Category 2	Service Penetration
								Category 3	Metal Pipes
				BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the be This information was deemed to be correct at the time of publication. Should any data come to BOSS				Test Standard	AS1530.4-2014/AS4072.1
		Tertiary Fire Stopping Product		attention relating to the fire resist	tance or performance o	f the product described, BOSS Fire & Saf Safety strive to constantly improve and de	ety Pty Ltd reserve the		CSIRO-2990B
				information may change without	notice.	, , , , , , , , , , , , , , , , , , , ,		Drawing Number	W-SP-MET-002
				The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591			Product DWG ID	HPE-018	
							Drawn By	EG Rev 03	
				Copyright © 2020 BOSS Fire & S				Date of Issue	23/09/2020