



OTHER APPLICABLE SUBSTRATES					
AFS	PRONTO	MASONRY	CONCRETE	ACC/HEBEL	SPEEDPANEL

Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	Wall (See Applicable Substrates)	FireMastic-300™	<b>Min 96mm or 116mm Thick Walls:</b> -FR Plasterboard / GIB -Shaftwall / Shaftliner -Concrete -Solid & Hollow Masonry -AFS  <b>Walls with Build Up to Min 96mm or 116mm:</b> -Speedpanel & Korok -AAC / Hebel -Pronto Panel -Supa Panel  <b>Build up options - 100mm clearance from perimeter of service:</b> -BOSS Batt -FR Plasterboard -Calcium Silicate Board -Shaftwall / Shaftliner	96mm for -/90/90 116mm for -/120/120	-/90/90 -120/120	Steel Copper & Iron Pipes - 32mm - 80mm Steel Copper & Iron Pipes - 80mm - 159mm	
2	Steel Copper & Iron Pipes - 32mm-80mm	-20mm x 20mm Surface Fillet					
3	Steel Copper & Iron Pipes - 80mm-159mm	-Annular Gap Min 26mm Depth					
4	FireMastic-300™	-Both Sides of wall					
5	P40-MAK Wrap 300mm Both Sides to suit 32mm-80mm Pipes						
6	P40-MAK Wrap 600mm Both Sides to suit 80mm-159mm Pipes						
7	BOSS Batt - 2x 50mm Layers - Used to firestop oversized apertures						
		<b>Secondary Fire Stopping Product</b>					
		P40-MAK Wrap					
		<b>Tertiary Fire Stopping Product</b>					
		BOSS Batt					

**LIMITATION**  
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.  
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591  
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

<b>Sales &amp; Technical</b>	1300 502 677		
<b>International</b>	+61 2 9531 8591		
<b>Web</b>	bossfire.com		
<b>Drawing Information:</b>			
<b>Category 1</b>	Wall		
<b>Category 2</b>	Service Penetration		
<b>Category 3</b>	Metal Pipes		
<b>Test Standard</b>	AS1530.4-2014/AS4072.1		
<b>Test Reference</b>	FAS 190346 R1.4		
<b>Drawing Number</b>	W-SP-MET-010		
<b>Product DWG ID</b>	FM3-012		
<b>Drawn By</b>	EG	<b>Rev</b>	02
<b>Date of Issue</b>	12/02/2021		