



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3	Fire Rated Plasterboard, Concrete & Masonry FireMastic-HPE™ - Depth of Plasterboard 20mm OD PEX Pipe	FireMastic-HPE™	Fire Rated Plasterboard, Concrete & Masonry	Min 90mm Thick (FRL -/60/90) Min 96mm Thick (FRL -/90/90)	Up to FRL -/90/90	20mm OD PEX Pipe	Aperture 60mm
		Secondary Fire Stopping Product					
		Tertiary Fire Stopping Product					

LIMITATION
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Wall		
Category 2	Service Penetration		
Category 3	Plastic Pipes		
Test Standard	AS1530.4-2014/AS4072.1		
Test Reference	CSIRO COT2923/COT2967		
Drawing Number	W-SP-PLS-005		
Product DWG ID	HPE-015		
Drawn By	EG	Rev	04
Date of Issue	14/09/2020		