



| Component Schedule | Component Name | Primary Fire Stopping Product | Applicable Substrates | Min Substrate Thickness (If Applicable) | Applicable FRL | Service Specifications | Limitations | | 066 |
|-----------------------|---|---|-----------------------|---|-------------------------------|---|---|----------------------|------------------------------|
| 3 | Wall (See Applicable Substrates) PenoPatch™ 100mm 12mm Nails or Screws depending on substrate Power Cables (See Service Specifications) | PenoPatch™ 100mm Secondary Fire Stopping Product | | 100mm | -/60/30 -/60/60 -/30/30 | PenoPatch™ 100mm - 50mm Aperture: | PenoPatch to be fixed using two masonry nails (min 12mm long). In AAC / Hebel, Speedpanel & Korok wall PenoPatch to be fixed using two metal screws | | |
| | | | | | | - Bundle 3 x PVC/PVC Sheathed 5mm x 1.5mm² Power Cable (FRL -/60/60 Config A) or | | PAS | SIVE FIRE |
| | | | | | | - Bundle 3 x EPR/PO Sheathed 5mm x 1.5mm² Power Cable (FRL -/60/30 Config A, FRL -/60/60 Config B) or | | Sales & Technical | 1300 502 677 |
| | | | | | | | | International | +61 2 9531 8591 |
| | | | | | | - Bundle 3 x XLPE/EVA Sheathed 5mm x 1.5mm² Power Cable (FRL -/60/60 Config A) or | | Web | bossfire.com |
| | | | | | | - Single PVC/PVC Sheathed 1mm x 95mm² Power Cable (FRL -/60/30 Config A) or | | Drawing Information: | |
| | | | | | | - Single PVC/PVC Sheathed 1mm x 185mm² Power Cable (FRL -/30/30 Config A) | | Category 1 | Wall |
| | | | | | | | | Category 2 | Service Penetration |
| | | | | LIMITATION | | | | Category 3 | Power Cables |
| | | | | BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice. The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591 | | | | Test Standard | AS1530.4: 2014/AS4072.1-2005 |
| | | Tertiary Fire Stopping Product | | | | | | Test Reference | FAS 190100 |
| | | | | | | | | Drawing Number | W-SP-POW-017 |
| | | | | | | | | Product DWG ID | PP-008 |
| | | | | | | | | Drawn By | EG Rev 04 |
| | | | | Copyright © 2020 BOSS Fire & S | | | | Date of Issue | 01/07/2021 |