



Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1	75mm AAC / Hebel	Cable Transit CT120 - 102mm x 102mm	AAC / Hebel	75mm	FRL -/120/30	Aluminium Core Power Cables -2 x 70mm ² Conductor -2 x 120mm ² Conductor -2 x 185mm ² Conductor -2 x 240mm ² Conductor	Aperture 110mm x 110mm
2	BOSS Batt						
3	Bulge Head screw with Washer						
4	Cable Transit Bracket						
5	FireMastic-300™ - 25mm Death						
6	2x Aluminium Cable 70mm ²						
7	2x Aluminium Cable 120mm ²						
8	2x Aluminium Cable 185mm ²						
9	2x Aluminium Cable 240mm ²						
10	Cable Transit CT120						
		Secondary Fire Stopping Product					
		BOSS Batt					
		Tertiary Fire Stopping Product					
		FireMastic-300™					

LIMITATION
 BOSS Fire & Safety Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Fire & Safety's attention relating to the fire resistance or performance of the product described, BOSS Fire & Safety Pty Ltd reserve the right to amend this document or drawing. BOSS Fire & Safety strive to constantly improve and develop products so this information may change without notice.
 The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591
 Copyright © 2020 BOSS Fire & Safety Pty Ltd. All rights reserved.

Sales & Technical	1300 502 677		
International	+61 2 9531 8591		
Web	bossfire.com		
Drawing Information:			
Category 1	Wall		
Category 2	Service Penetration		
Category 3	Power Cables		
Test Standard	AS1530.4:2014/AS4072.1-2005		
Test Reference	RIR FRT180473		
Drawing Number	W-SP-POW-020		
Product DWG ID	CT-001		
Drawn By	EG	Rev	03
Date of Issue	24/08/2021		