

FireMaster® FastWrap® XLS Grease Duct Installation and Design Guidelines

Thermal Ceramics



Release Date: August 2021



Table of Contents

- 1) Product Description
- 2) Product Features
- 3) Specifications - Division 23 07 13 – Duct Insulation
- 4) Physical Characteristics and Performance
- 5) Grease Duct Listings/Building Code Report
- 6) Codes and Test Standards
- 7) Storage
- 8) Installation
 - a) Materials and Equipment
 - b) General
 - i) Installation on Grease Duct per ASTM E2336 and CAN/ULC S144
 - ii) 2 & 3-Sided Wrap Installation
 - iii) Mechanical Attachment Methods
 - (1) Banding
 - (2) Pinning
 - iv) Access Doors
 - (1) Field Fabricated Access Doors
 - (2) Prefabricated Access Doors
 - v) Through Penetration Firestop System
 - vi) Support Hanger Systems
- 9) Maintenance and Repair
- 10) Limitations

FireMaster FastWrap XLS Introduction

Grease Duct Enclosure System

1. Product Description

FireMaster FastWrap XLS is the newest development in our portfolio of industry leading fire-rated duct passive fire protection from Morgan Advanced Materials. This new 1.5" thick (38 mm) matte black colored duct wrap design features a 25% lighter material weight than existing comparable duct wraps, making it the lightest weight system available in the market, tested and listed for use in kitchen exhaust applications to provide zero clearance to combustible construction.

FireMaster FastWrap XLS lightweight system will reduce potential installer fatigue, decrease potential for accidents at job sites, and assist in reducing installation time. The flexible blanket system is composed of high temperature fibers classified for applications up to 2192°F (1200°C). It is fully encapsulated in a matte black, durable fiberglass reinforced foil facing for improved aesthetics, ease of handling and installation.

The core fibers in FireMaster FastWrap XLS are manufactured using Thermal Ceramics' patented Superwool® fiber, a low bio persistent fiber. FireMaster FastWrap XLS is under Intertek's Follow-Up Service Program to ensure the consistent quality essential to this life-safety application.

2. Product Features

- Provides a 2-hour enclosure and firestop system for kitchen exhaust ducts
- Tested to ASTM E2336
- Provides zero clearance to combustibles throughout the installed system
- Complies with IMC, NFPA-96, UMC, CMC, CNBC
- Thin and lightweight; 1.5" (38 mm) thick, 4.4 pcf (70 kg/m³) density
- Encapsulated in a fiberglass reinforced, matte black foil facing for improved aesthetics
- Contours easily to complex duct designs
- Intertek Listed Grease duct installation with butt joints at all seams on both layers
- Taping of joints is not required.
- Cuts easily with less dust for clean jobsite installation
- UL Environment validated as a 'Low VOC Emitting Material' and 'Mold Resistant'

3. Specifications - Division 23 07 13 – Duct Insulation

FireMaster FastWrap XLS is a flexible high temperature insulation rated to 2192°F (1200°C) that is fully encapsulated in a matte black fiberglass reinforced foil facing. Installation shall be in strict accordance with manufacturer's published installation instructions, Intertek Listings, and shop drawings. The duct enclosure system shall be listed by Intertek per ASTM E2336, CAN/ULC S144 and CAN/ULC S115 for a 2-hour rating and zero clearance to combustibles and tested per ASTM E84 or UL 723 for a flame/ smoke rating less than 25/50. Insulation shall have a nominal thickness of 1.5" (38 mm) and density of 4.4 pcf (70 kg/m³).

4. Physical Characteristics and Performance

Availability:	1.5" x 24" x 25' Rolls (38 x 610 x 7620 mm)
Density:	4.4 pcf (70 kg/m ³)
Thickness:	1.5" (38 mm)
Color:	Matte black foil facing with silver text
Surface Burning:	< 25/50 (per ASTM E84)
R Value (at 75°F)	6.5 per layer (per ASTM C518)
Low VOC's	Validated, per CA Section 01350
Mold Resistant	Validated, per ASTM C1338

5. Grease Duct Listings/Building Code Report

The following design listings and Building Code Report are available for FireMaster FastWrap XLS:

Description	Laboratory	Listing/Report Number
ASTM E2336, Grease Duct Assembly	Intertek	TC/BI 120-04
ASTM E814, Through Penetration Firestops	Intertek	TC/BI 120-07
ASTM E814, CAN/ULC-S115, Through Penetration Firestops	Intertek	TC/BI 120-06
CAN/ULC-S144, Grease Duct Assembly	Intertek	TC/BI 120-05
Grease Duct Code Compliance Report	Intertek	CCRR No. 0402

6. Codes and Test Standards

FireMaster FastWrap XLS has been tested in accordance with the following, as required for compliance with US and Canadian grease duct certification:



ASTM E2336	Standard Test Methods for Fire Resistive Grease Duct Enclosure Systems
ASTM C518	Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus
ASTM E84	Test Method for Surface Burning Characteristics of Building Materials
ASTM E119	Test Methods for Fire Tests of Building Construction and Materials
ASTM E136	Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C
ASTM E814	Test Method for Fire Tests of Penetration Firestop Systems
ASTM C411	Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation
CAN/ULC-S144	Standard Method of Fire Resistance Test – Grease Duct Assemblies
CAN/ULC-S115	Standard Method of Fire Tests of Firestop Systems
International Mechanical Code (IMC)	2012 – 2021 Editions
International Building Code (IBC)	2012 – 2021 Editions
IAPMO Uniform Mechanical Code (IAPMO UMC)	2012 – 2021 Editions
NFPA 96 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations	2014 – 2021 Editions
National Building Code of Canada	2015 & 2020 Editions

7. Storage

FireMaster FastWrap XLS is supplied in corrugated cardboard cartons. It must be stored in a dry warehouse environment on pallets. Pallets should not be stacked. Do not store in outside conditions.

8. Installation

FireMaster FastWrap XLS shall be installed by a qualified contractor in accordance with manufacturer's instructions and laboratory design listings.

a) Materials and Equipment

- FireMaster FastWrap XLS
- Aluminum foil tape, foil scrim tape or UL 181 tape (black recommended)
- Glass filament reinforced tape (optional)
- Carbon steel or stainless-steel banding material, minimum 0.5" (13 mm) wide, minimum 0.015" (0.4 mm) thick, with steel banding clips
- Hand banding tensioner and crimping tool
- Minimum 12 gage (3 mm) steel insulation pins; steel speed clips, minimum 1.5" (38 mm) square or 1.5" (38 mm) diameter, or equivalent sized cup-head pins
- Capacitor discharge stud gun
- Approved firestop sealant




b) General

Cut edges of the blanket shall be taped with an approved tape to prevent exposed edges of the insulation from absorbing grease and moisture in the event of a compromised grease duct joint or condensation. Overlaps and/or tightly butted joints are used to block heat transfer in the event of duct deformation resulting from thermal expansion. Filament tape is suggested to hold the blanket in place until steel banding or pinning is installed to permanently secure the blanket. Metal banding is not required on the inner layer.

i) Installation on Grease Duct per ASTM E2336 and CAN/ULC S144 (Figure 1)

System requires two layers of insulation applied directly to the duct with tight butt joints minimum 1.5" (38 mm) compression at all seams on both layers. The first layer of insulation is cut to a length sufficient to wrap around the duct and provide a tight butt joint where the blanket ends meet. Adjacent blankets on the first layer are tightly butted together with longitudinal seams offset minimum 6" (150 mm). The second layer of insulation is installed in the same method as the first layer, with seams between layers offset a minimum of 6" (150 mm). Banding and/or pinning per Section C is used to permanently secure the insulation to the duct.

Figure 1: FireMaster FastWrap XLS Commercial Kitchen Grease Duct Enclosure System Shaft Alternative / Zero Clearance to Combustibles



TWO LAYER INSTALLATION (Grease Duct per ASTM E2336)

XL001-0

LEGEND

1	Two Layers of FastWrap XLS Insulation for ASTM E2336 and CAN/ULC S144 Grease Duct Enclosures
2	Steel banding minimum 1/2" wide by 0.015" thick.
3	Tight butt joints (no overlap) at perimeter and longitudinal joints; both layers
4	Min. 3/8" diameter hanger rod
5	Min. 2" x 2" x 1/8" angle


The integrity of Firemaster duct systems is limited to the quality of the installation.

ii) 2 & 3-Sided Wrap Installation (Figure 2)

When space does not allow for a complete wrap applied to the duct on all four sides, the FireMaster FastWrap XLS may be

used for 2 or 3-sided installations with mechanical attachment to a rated concrete or CMU assembly. (See Figure 2 for installation details.)

Figure 2: FireMaster FastWrap XLS Commercial Kitchen Grease Duct Enclosure System Shaft Alternative / Zero Clearance to Combustibles 2 and 3-Sided Wrap Detail for Attaching to Walls and/or Ceilings.



*The integrity of FireMaster duct systems is limited to the quality of the installation

iii) Mechanical Attachment Methods

- **Banding** - Minimum 0.5" (13 mm) wide carbon steel or stainless-steel banding, 0.015" (0.4 mm) thick, is placed around the entire perimeter of the insulated duct on maximum 10.5" (270 mm) centers and 1.5" (38mm) from each blanket edge or 1.5" (38 mm) from each collar edge when using the butt joint and collar method. The banding is placed around the blanket and tightened to firmly hold the FastWrap XLS in place against the duct, but not cause any cutting or damage to the blanket.
- **Pinning** - Pinning on all sides of the duct may be used as an alternative to banding. For ducts wider than 24" (610 mm) pinning is required on the bottom of horizontal runs, or on one side of vertical runs (in addition to steel banding). When applicable, 12-gage (3 mm) copper-coated, steel pins are installed on 12" (305 mm) centers along the width of the duct and 10.5" (270 mm) centers along the length of the duct. Pins that extend beyond the outer blanket layer shall be turned down or the excessive length cut off to prevent sharp edges. Shoot through pins (cup head pins) may be used in conjunction with steel banding to prevent blanket sag.

iv) **Access Doors**

- **Field Fabricated Access Doors** - Each access door assembly has four threaded rods 0.25" (6 mm) in diameter and 5" (127 mm) in length, with one welded to each corner of the door opening. Hollow steel tubes, 4.5" (114 mm) long is installed outside the access cover plate and over the threaded rods. Four 12 gage (3 mm) and 5" (127 mm) long steel insulation pins are welded to the access cover plate corners to allow for installation of the three layers of FireMaster FastWrap XLS. One layer of FireMaster FastWrap XLS is cut to approximately the same size as the access panel and impaled over the insulation pins on the panel. A second layer of FireMaster FastWrap XLS is cut to overlap the first layer a minimum of 1.5" (38 mm) per side. It is essential that the first and second layer fit tightly against

the surrounding wrap with no through openings. The third and outside layer should be cut to overlap the second insulation layer by a minimum of 1.5" (38 mm) per side. Minimum 1.5" (38 mm) round or square insulation clips are installed on the insulation pins to secure the three layers of insulation to the access cover plate. All cut edges of the insulation shall be taped with minimum 3" (75 mm) wide aluminum foil tape. Wing nuts and washers are installed on the four threaded rods and tightened against the hollow steel tubes to seal the access cover plate to the duct.

- Prefabricated Access Doors** –Install a Listed inner access door per manufacturer's installation instructions. Once installed, the access door is to be insulated with 3 layers of FireMaster FastWrap XLS. The inner layer of insulation should match the dimensions of the access door. Each following layer should be stepped such that insulation dimensions are 3" (75 mm) wider and taller than the previous layer. Access door should be fitted with two (2) minimum 6" (15 mm) long, 3/8" (10 mm) diameter steel threaded rods, passing through blanket layers. Install a 16-gage (2 mm) cover plate having dimensions of the 3rd layer of insulation with holes drilled to match the 2 threaded rods attached to the access door. Fasten the cover plate, using washers and wing nuts.

v) Through Penetration Firestop System

When the duct penetrates a fire rated assembly, an approved firestop system must be employed. Firestops that are listed for use with FireMaster FastWrap XL may also be used with FireMaster FastWrap XLS duct systems, providing that the FireMaster FastWrap XLS filler blanket used through the supporting construction or used as packing material is compressed by a factor of 1.36 more than required by the FastWrap XL listings. Table 1 provides a summary of listed firestop design listings which can be found by searching the UL Product iQTM database.

Additional firestops may be installed per Figure 3 and 4. Prior to installing any firestop system, the surfaces of all



openings and penetrating items must be clean and dry. The FireMaster FastWrap XLS filler blanket must be compressed into the annular space. The packing material must be recessed a minimum depth from the surface of the concrete or gypsum assembly. The recessed opening must be filled with a minimum thickness of an approved firestop sealant.

The packing material type and compression, minimum recess (typically 0.25" (6 mm)), and approved firestop sealant and thickness (typically 0.25" (6 mm)) shall be as specified in an approved firestop design listing. When there is not sufficient annular space around the duct to run the


FireMaster FastWrap XLS enclosure system continuous through the fire rated assembly, the enclosure may terminate above and below the floor/ceiling assembly or on either side of a wall assembly as shown in Figure 3 and 4.

When this method is used, the FireMaster FastWrap XLS must be mechanically attached on either side of the fire rated assembly using one of the attachment methods described in Section 8iii, spaced a maximum of 1.5" (38 mm) from the fire rated assembly.

Table 1: 2-Hour Grease Duct Firestop Designs per ASTM E814/UL 1479


UL Listing	Construction	Termination	Firestop Sealant
C-AJ-7018	Concrete/CMU	Wrap Through	STI, Nelson
C-AJ-7021	Concrete/CMU	Terminate at	STI, Tremco, DAP
C-AJ-7098	Concrete/CMU	Wrap Through	Hilti, Rectorseal, STI, Tremco
C-AJ-7153	Concrete/CMU	Terminate at	Hilti
F-C-7036	Wood/Gypsum Floor	Wrap Through	Nelson, Hilti, Rectorseal, STI, Tremco, FireMaster Putty
W-L-7041	Gypsum Wall	Wrap Through	Tremco
W-L-7099	Gypsum Wall	Wrap Through	STI
W-L-7121	Gypsum Wall	Wrap Through	Nelson, Hilti, Rectorseal, STI, Tremco

Figure 3: FireMaster FastWrap XLS Commercial Kitchen Grease Duct Enclosure System 2-Hour Floor Penetration Firestop Systems



- 1 – Grease Duct
- 4 – FireMaster FastWrap XLS, 2-Layers, 4.4 pcf density
- 5 – 2-hour Floor Assembly
- 7A – FireMaster FastWrap XLS filler blanket, unencapsulated, 50% compression
- 7B – 0.25" layer of Approved Firestop Sealant

Figure 4: FireMaster FastWrap XLS Commercial Kitchen Grease Duct Enclosure System 2-Hour Wall Penetration Firestop Systems.



- 1 – Grease Duct
- 4 – FireMaster FastWrap XLS, 2-Layers, 4.4 pcf density
- 5 – 2-hour Wall Assembly
- 7A – FireMaster FastWrap XLS filler blanket, unencapsulated, 50% compression
- 7B – 0.25" layer of Approved Firestop Sealant

vi) Support Hanger Systems

Trapeze support hangers shall be spaced on maximum 60". (1500 mm) centers. Hanger rods or straps shall be anchored with steel drop in or wedge expansion type masonry anchors. Threaded rods should be spaced a minimum of 1" (25 mm) from the insulated grease duct. No additional protection is required for hangers and supports meeting the requirements of the Table below.

<i>Hanger Cross Section</i>	<i>Maximum Perimeter, in (mm)</i>	<i>Trapeze Support (or equivalent Yield Strength), in (mm)</i>
<i>3/8" (10 mm) threaded rod</i>	<i>144" (3658 mm)</i>	<i>2" x 2" x 1/8" angle (51 x 51 x 3 mm)</i>

9. Maintenance and Repair

No maintenance is required when installed in accordance with Morgan Advanced Materials' installation instructions. If damage is limited to the foil facing, approved tape can be used to repair the foil facing. If an area of blanket is found to be damaged the following procedure must be incorporated: If the damaged area is larger than 8" x 8" (203 x 203 mm), the entire wrap section must be

removed and replaced according to Morgan Advanced Materials installation instructions. If the damaged area is small (less than 8" x 8" (203 mm x 203 mm), the damaged area must be cut away and replaced with a new section 1" (25 mm) larger in length and width than the cut out, such that the new section can be compressed tightly into the cut-out area. All cut edges of the new section must be taped and sealed with an approved tape. The new section must be held in place with either pinning or banding per Morgan Advanced Materials installation instructions.

10. Limitations

Morgan Advanced Materials FireMaster FastWrap XLS shall be installed in accordance with these installation instructions and appropriate laboratory design listings. The integrity of FireMaster FastWrap XLS systems is limited to the quality of the installation.

* For personal protective equipment recommendations, please see Morgan Advanced Materials SDS Number 350.

Thermal Ceramics, FireMaster, FastWrap and Superwool are trademarks of Morgan Advanced Materials. FireMaster products are manufactured by Thermal Ceramics, a business of Morgan Advanced Materials and are distributed by authorized distributors.

Morgan Advanced Materials

Morgan Advanced Materials is a global engineering company.

We apply world-class materials science and manufacturing expertise to solve technical challenges that our customers face everyday.

We work in the electronics, energy, healthcare, industrial, petrochemical, security and transport markets, forming close collaborative relationships with our customers.

Morgan is a global leader in materials science and application engineering.

What differentiates us?

Advanced material science and processing capabilities.
Extensive applications engineering experience.

A strong history of innovation and reinvention.
Consistent and reliable performance.

A truly global footprint.
We find and invest in the best people.



DISTRIBUTED BY

www.potters.co.nz

0800 POTTERS | info@potters.co.nz

Auckland, Hamilton, Wellington + Christchurch