

BRANZ Appraised Appraisal No. 797 [2020]

MAMMOTH[™] INSULATION

Appraisal No. 797 (2020)

This Appraisal replaces BRANZ Appraisal No. 797 (2014)

BRANZ Appraisals

Technical Assessments of products for building and construction.



InZone Industries Ltd PO Box 204 289 Highbrook Auckland Tel: 09 273 2308 Freephone: 0800 MAMMOTH (0800 626 668) Email: info@mammoth.co.nz Web: www.mammoth.co.nz



BRANZ

1222 Moonshine Rd, RD1, Porirua 5381 Private Bag 50 908 Porirua 5240, New Zealand Tel: 04 237 1170 branz.co.nz





Product

1.1 Mammoth[™] Insulation is a range of polyester fibre thermal insulating material. The insulation is pre-cut to suit a range of thermal insulation requirements and framing set-outs in walls, ceilings and roofs of buildings.

Scope

2.1 Mammoth[™] Insulation has been appraised as thermal insulating material for framed or partframed walls, ceilings, and roofs of domestic and commercial buildings.

Building Regulations

New Zealand Building Code (NZBC)


3.1 In the opinion of BRANZ, Mammoth[™] Insulation if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1 (a) not less than 50 years and B2.3.1 (b) 15 years. Mammoth[™] Insulation will meet these requirements. See Paragraphs 8.1 and 8.2.

Clause E3 INTERNAL MOISTURE: Performance E3.3.1. Mammoth[™] Insulation will contribute to meeting this requirement. See Paragraphs 13.1 and 13.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Mammoth[™] Insulation meets this requirement and will not present a health hazard to people.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1 (a) and H1.3.2 E. Mammoth[™] Insulation will contribute to meeting these requirements. See Paragraphs 14.1 and 14.2.





Technical Specification

4.1 Mammoth[™] Insulation is manufactured from non-woven, thermally-bonded polyester fibres. The fibres are blended, either carded or Airlaid, and then thermally bonded and machine slit to the required width and length to produce segments and blankets. Mammoth[™] Insulation is available as set out in Table 1.

Table 1: Mammoth™ Insulation Product Range

R-value	Nominal thickness (mm)	Width (mm)	Length (mm)	Density (kg/m³)
Ceiling Blanket				
1.8*	115	870	11,495	7.8
2.6	175	870	8,620	7.1
2.9*	185	870	8,620	7.6 or 8.1
3.2*	200	870	8,620	5.0
3.3	210	870	8,620	7.6
3.6*	225	870	7,470	8.0
4.0*	240	870	5,747	8.3
Skillion Roof Sections				
2.9	115	560 or 860	1,200	32.8
3.2	165	570 or 870	1,200	15.2
Wall Sections				
1.9	90	360 or 560	760	16.7
2.0	90	360 or 560	760	22.2
2.2	90	360 or 560	760	26.7
2.5*	90	360 or 560	760	40.0
2.8	140	360 or 560	760	15.0
Wall Blanket				
2.2	90	360 or 570	9,870 or 10,800	21.6
2.6	140	380 or 580	8,550 or 7,470	10.7

*These products can be manufactured on either a carded or Airlaid production line. The performance criteria have been evaluated and found to be the same.

- 4.2 Mammoth[™] Insulation is off-white in colour and is packaged in compression packaging with labelling in compliance with AS/NZS 4859.1.
- 4.3 Accessories used with Mammoth[™] Insulation, which are supplied by the installer, are plastic strapping and fixings.

Handling and Storage

- 5.1 Mammoth[™] Insulation must be stored under cover and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.
- 5.2 In general, insulation products are sensitive to the length of time they are stored under compression packaging. Product that does not recover to its nominal thickness may not achieve the stated thermal resistance (R-value).



Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for Mammoth™ Insulation. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Mammoth[™] Insulation is intended for use as thermal insulation to meet the requirements of the NZBC. Mammoth[™] Insulation can be used to meet the minimum schedule method R-values of the NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Greater construction R-values can be achieved where specific design is used. For construction R-values, refer to the BRANZ House Insulation Guide. Product R-values and dimensions are given in Table 1.
- 7.2 Mammoth[™] Insulation R-values have been determined by testing to AS/NZS 4859.1, which is an acceptable method in NZBC Acceptable Solution H1/AS1.
- 7.3 Mammoth[™] Insulation blanket and section products are designed to be friction-fitted between wall, ceiling or roof framing. Mammoth[™] Insulation can also be laid directly over ceiling lining, over ceiling battens or joists/truss chords. In other horizontal situations, the insulation must be adequately supported by a suitable durable material. Mammoth[™] Insulation Skillion Roof Insulation is designed to be friction-fitted between rafters.
- 7.4 Where the insulation is installed in exterior walls, the insulation material nominal thickness must be selected to provide a snug close fit, which touches all sides of the insulation cavity between the wall underlay and the interior wall lining.
- 7.5 Where the insulation is retrofitted in external walls without a wall underlay, and with direct-fixed claddings, the insulation must be at least 20 mm thinner than the framing to allow a gap of at least 20 mm between the insulation and the wall cladding. Horizontal straps must be stapled into the sides of the wall studs at 300 mm centres maximum as support before the insulation is installed. Refer also to NZS 4246, Section 5.4.2.
- 7.6 When the insulation is installed in a wall with a drained cavity, it is recommended that specific wall products with a controlled nominal thickness be used. Where the stud spacings are greater than 450 mm, an intermediate means of restraining the insulation from bulging into the cavity must be installed in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.5.
- 7.7 To prevent moisture transfer and to provide roof ventilation, a separation of 25 mm minimum is required between the insulation and any rigid substrate or flexible roof underlay. Selecting the specifically designed skillion roof insulation product with a controlled thickness can assist with this requirement.
- 7.8 The building envelope must be constructed to ensure the insulation remain dry during installation and throughout the life of the building.
- 7.9 The clearance requirements for heating appliances and downlights must be met and reference made to the manufacturer's instructions and NZS 4246.

Durability

8.1 The durability assessment of Mammoth[™] Insulation to meet the requirements of the NZBC is based on the difficulty of access and replacement, and the ability to detect failure of the insulation, both during normal use and maintenance of the building.

Serviceable Life

8.2 Where the building is maintained so that the provisions of the NZBC E2 and E3 Clauses are met, and where the insulation is not crushed or exposed to conditions that will diminish its thermal performance, then Mammoth[™] Insulation can expect to have a serviceable life of at least 50 years.



Maintenance

9.1 Insulation that has become damp must be removed and the cause of dampness repaired. Cavities must be clean and dry before refitting the insulation after drying or replacing with new Mammoth™ Insulation. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.

Prevention of Fire Occurring

10.1 Separation or protection must be provided to Mammoth[™] Insulation from heat sources such as fireplaces, heating appliances and chimneys. Part 7 of NZBC Acceptable Solution C/AS1 and C/AS2, and NZBC Verification Method C/VM1 provide methods for separation and protection of combustible materials from heat sources.

Downlights

- 10.2 Recessed luminaries shall be of luminaire type and be installed in accordance with NZBC Acceptable Solutions C/AS1 and C/AS2, Section 7.4.
- 10.3 Insulation materials must maintain a clearance of 100 mm to undefined recessed luminaries in existing buildings.

Fire Affecting Areas Beyond the Fire Source

Control of Internal Fire and Smoke Spread

11.1 Polyester insulation is a combustible insulant, therefore the interior surface finish must achieve a Group Number of not more than 3 as per NZBC Acceptable Solution C/AS1 Section 4.3. Mammoth™ Insulation meets this requirement and will not need to be enclosed by an interior surface lining. Table 4.3 of NZBC Acceptable Solution C/AS2 details the required Group Numbers for internal surface finishes. Where a better Group Number than 3 is required, the insulation must be lined with a suitable material.

External Moisture

- 12.1 The total building envelope must be weathertight and comply with the requirements of NZBC Clause E2 to ensure that the insulation remains dry in use.
- 12.2 The moisture content of the construction materials at the time of installing and enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 10.2 a), or lower moisture content if required by the lining manufacturer.

Internal Moisture

- 13.1 Buildings must provide an adequate combination of thermal resistance, ventilation and space temperature to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate. This does not apply to Communal Non-residential, Commercial, Industrial, Outbuildings or Ancillary buildings.
- 13.2 Roofs and walls of housing complying with the Schedule Method for Compliance with Clause H1.3.2 E will have adequate thermal resistance. Other buildings may require more thermal insulation to satisfy the requirements of NZBC Acceptable Solution E3/AS1 than that to satisfy the energy efficiency provisions alone.

Energy Efficiency

- 14.1 Mammoth™ Insulation will contribute to meeting the requirements of NZBC Clause H1 Performance H1.3.1 (a) and H1.3.2 E by compliance with NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1.
- 14.2 Mammoth[™] Insulation R-values have been determined by BRANZ testing to AS/NZS 4859.1 and are given in Table 1.

Installation Information

Installation Skill Level Requirements

15.1 All design and building work must be carried out in accordance with the Mammoth[™] Insulation Technical Literature and this Appraisal. All building work must be undertaken by competent and experienced tradespersons conversant with Mammoth[™] Insulation.

General

- 16.1 Installation of Mammoth[™] Insulation must be in accordance with the Technical Literature and this Appraisal. NZS 4246 should be used as a guide for installing insulation in residential buildings.
- 16.2 The product must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less.
- 16.3 Mammoth[™] Insulation must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.
- 16.4 Mammoth[™] Insulation is supplied in section and blanket form (see Table 1) and allows the product to be cut or torn to suit wall, ceiling or roof framing. The insulation must be neatly friction-fitted between framing members so that the potential for gaps and convective heat loss is reduced. In wall cavities, the insulation must be neatly friction-fitted between framing members to prevent sagging and thermal convection. In ceiling or roofs, the insulation must be fitted between framing members or fitted over framing members. The insulation must extend to the external top plate. The insulation must not be folded, tucked or compressed. A close even fit provides the most efficient thermal performance. Wherever possible, the insulation should be fitted beneath wiring or plumbing.
- 16.5 The clearance requirements for heating appliances, light fittings and downlights must be followed. Refer also to NZS 4246.

Inspections

16.6 The Technical Literature, this Appraisal and NZS 4246 must be referred to during the inspection of Mammoth™ Insulation installations.

Health and Safety

17.1 Mammoth[™] Insulation is safe to handle. NZS 4246 gives guidance for health and safety requirements such as personal protective clothing and installation hazard assessment.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 18.1 BRANZ has carried out thermal resistance testing of Mammoth™ Insulation in accordance with AS/NZS 4859.1.
- 18.2 BRANZ has carried out reaction to fire testing in accordance with ISO 5660 and fire testing in accordance with ISO 9705 of InZone Industries Ltd's polyester insulation to determine the group number of Mammoth[™] Insulation.

Other Investigations

- 19.1 An assessment of the durability of Mammoth[™] Insulation has been made by BRANZ technical experts.
- 19.2 The manufacturer's Technical Literature and Installation Instructions have been reviewed by BRANZ and found to be satisfactory.
- 19.3 Site inspections have been undertaken by BRANZ to assess the practicability of installation.



Quality

- 20.1 The manufacture of Mammoth[™] Insulation has been examined by BRANZ, including methods adopted for quality control. Details of the manufacturing processes, and quality and composition of the raw materials used were obtained and found to be satisfactory.
- 20.2 InZone Industries Ltd is responsible for the quality of the product supplied.
- 20.3 Quality of installation of the product on site is the responsibility of the installer.
- 20.4 Maintenance of the building is the responsibility of the building owner.

Sources of Information

- AS/NZS 4859.1: 2002 Materials for the thermal insulation of buildings.
- BRANZ House Insulation Guide, Fifth Edition 2014.
- BRANZ Bulletin No. 525 Preventing moisture problems in timber-framed skillion roofs.
- NZS 4246: 2016 Energy Efficiency Installing bulk thermal insulation in residential buildings.
- Ministry of Business, Innovation and Employment Records of Amendments Acceptable Solutions, Verification Methods and Handbooks.
- The Building Regulations 1992.





In the opinion of BRANZ, Mammoth[™] Insulation is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to InZone Industries Ltd, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

- 1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
- 2. InZone Industries Ltd:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
- 3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by InZone Industries Ltd.
- 4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
- 5. BRANZ provides no certification, guarantee, indemnity or warranty, to InZone Industries Ltd or any third party.

For BRANZ

Chelydra Percy Chief Executive Date of Issue: 02 September 2020