

# BRANZ Type Test Summary

**This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of**

Potter Interior Systems  
9 McNab Street  
Penrose  
Auckland 1061  
New Zealand

- Test standard:** ISO 5660 Parts 1 and 2.
- Specimen name:** Heradesign Fine, Heradesign Superfine (15 mm and 35 mm), Heradesign Micro and Heradesign Macro.
- Specimen description:** Magnesite bonded wood wool.
- Orientation:** From the direction tested.

**A full description of the test specimen and the test results are given in BRANZ Test Report:**

Fire Test FH 5505-TT – Test dates 31 March, 8 April and 13 May 2014

**Regulatory authorities are advised to examine test reports before approving any product.**

**The test results were the basis for the following:**

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S

**Issue Date:**  
27 May 2014

**Expiry Date:**  
27 May 2019



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation.